



Product Service

CERTIFICATE

No. B 058029 0048 Rev. 01

Holder of Certificate: **ASSA ABLOY**
Entrance Systems AB
Lodjursgatan 10
SE-261 44 Landskrona
SWEDEN

Certification Mark:



Product: **Powered pedestrian doors**
Sliding Door Drive

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704012019708-01

Valid until: 2026-08-24

Date, 2021-08-25

(Mingmin Fan)

CERTIFICATE

No. B 058029 0048 Rev. 01

Model(s): SL521, SL521 ADS

Parameters:

Rated voltage: 100-240VAC
Rated frequency: 50/60Hz
Rated input power: 250W
Rated load: 150N
Performance Level: c (used for non-escape route functionality)
d (used for escape route functionality)
Category: 2
Durability: 1 000 000 cycle
Protection class: I
Temperature range: -20 up to +50°C
Degree of protection: IP20

The sliding door drive can be used in combination with the following doors:

Sliding Door Drive	Max.	Max.	Min.
	door leaf weight	Clear opening width	Clear opening width
SL521, SL521 ADS (used with single motor)	150kg*2	4000mm	900mm
	150kg*4	4000mm	1720mm
SL521, SL521 ADS (used with dual motor)	50kg*2	4000mm	900mm
	150kg*4	4000mm	1720mm
SL521, SL521 ADS (used with single motor and rubber band)	120kg*2	4000mm	900mm
	80kg*4	4000mm	1720mm
Remark: The model SL521 ADS can be only used in combination with ADS type door			

Tested according to: EN 16005:2012
DIN 18650-1:2010
DIN 18650-2:2010
EN ISO 13849-1:2015
EN 60335-1:2012/A2:2019
EN 60335-2-103:2015
AutSchR:1997