



Product Service

CERTIFICATE

No. B 058029 0049 Rev. 01

Holder of Certificate: **ASSA ABLOY**
Entrance Systems AB
Lodjursgatan 10
SE-261 44 Landskrona
SWEDEN

Certification Mark:



Product: **Powered pedestrian doors**
Sliding Door System
Model(s): **SL500, SL500 ADS, SL520,**
SL520 ADS, SL510, SL510 ADS

Parameters:
Rated voltage: 100-240VAC
Rated frequency: 50/60Hz
Rated input power: 250W
Rated load: 150N
Performance Level: d
Category: 2
Durability: 1 000 000 cycle
Protection class: I
Temperature range: -20 up to +50°C
Degree of protection: IP20

Tested according to: EN 16005:2012
EN ISO 13849-1:2015
EN 60335-1:2012/A2:2019
EN 60335-2-103:2015
DIN 18650-1:2010
DIN 18650-2:2010
AutSchR:1997

The product was tested on a voluntary basis and complies with the essential requirements.
The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.
All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704011830801-01
Valid until: 2026-08-24

Date, 2021-08-25

(Mingmin Fan)